

# USA SWIMMING

## MEASUREMENT CERTIFICATION OF PERMANENT RACING COURSE

City and State in which pool is located: ATLANTA, GEORGIA  
 Name of Pool Owner or Operator: CITY OF ATLANTA  
 Mailing Address: CITY HALL EAST, 8<sup>TH</sup> FLOOR, PONCE DELEON NE.  
 City, State, Zip: ATLANTA, GEORGIA 30308  
 Pool Name: ADAMSVILLE NATATORIUM  
 Pool Address (if different from above) 3201 M.L. KING DRIVE NW  
 City, State, Zip: ATLANTA, GEORGIA 30311

### RELEVANT USA SWIMMING REGULATIONS

- Rule 103.3.1.C Dimensional Tolerance: Against the required length, a tolerance of plus (+) 0.03 meters (1 and 3/16ths of an inch) in a vertical plane extending 0.3 meters (12 inches) above and 0.8 meters (2 feet, 7 and 1/2 inches) below the surface of the water at all points of both end walls.
- Rules 103.3.1.D When automatic officiating equipment touch pads are used at one or both ends, the course shall be of such length that ensures the required distance between the two touch pads or between either pad and the opposite end of the course.
- Rule 104.2.2.C (4) (a) The exact length of the course, measured by a steel tape or other acceptable measuring device in feet and inches and fractions of an inch, or in meters and centimeters, must be attested to by an accredited surveyor or engineer.
- Rule 104.2.2.C (4) (b) A statement of the conditions under which the course was measured must be included.
- Rule 104.2.2.C (4) (c) Where a moveable bulkhead is used, course measurement of each lane must be confirmed at the conclusion of the session during which the time was achieved. Confirmation of length before sessions, and at the conclusion of the meet may be attested to by that person designated or approved by the Referee or meet committee, and such measurements shall be kept on file for twelve (12) months thereafter if a national or world record is claimed.

**NOTE:** If two or more racing courses are offered in the same pool (i.e., 50m x 25y), a separate form for each course must be filed.

### MEASUREMENTS (ANSWER ALL QUESTIONS)

This is a  Long Course pool,  Short Course pool; and is  indoors,  outdoors.

With touch pads at  one end;  both ends;  without touch pads.

**SEE NOTE**

	LANE 1	LANE 2	LANE 3	LANE 4	LANE 5	LANE 6	LANE 7	LANE 8
YARDS	56.057	56.056	56.055	56.054	56.053	56.052	56.051	56.050
METERS	51.258	51.257	51.256	51.255	51.254	51.253	51.252	51.252
FEET	168' 2 1/16"	168' 2 1/16"	168' 2 1/16"	168' 2 1/16"	168' 2"	168' 2"	168' 2"	168' 2"

WATER DEPTH (IN FEET)

At starting end 7' 8"; at turning end 5' 1"; at course center 5' 3".

\*

POOL HAS A 4' MOVEABLE PLATFORM WHICH WAS IN THE CENTER OF THE POOL AT THE TIME OF SURVEY.

(continued on other side)

In my opinion, the provisions of USA Swimming Rules 103.3.1 and 104.2.2 as outlined on the previous page have been complied with in subject pool, with exceptions as follows:

NO EXCEPTIONS FOUND

NORMAL INDOOR CONDITIONS AT TIME OF SURVEY

Measurements were made on 10-8, 2003, at 11:00 AM under normal competitive temperature conditions and to an accuracy of at least .01 feet (1/8 inch or 3.00 mm) in short course pool and at least 5.0mm in long course pool.

At the time of measurement, I was not in the employ of the pool builder.

CERTIFIED TO By JULIAN D. GRACE

The following equipment was used for measurements: 200' STEEL TAPE AND 25' FIBERGLASS LEVEL ROD.

Signed: Jul. J. Grace

Check one:

Title/Degree: SURVEY DEPT. MANAGER

Registered Surveyor

Address: GREENHURNE Y O'MARA, INC. 2211 NEW MARKET

Registered Engineer

City, State, Zip: MARIETTA, GA 30067 PARKWAY, SUITE 108

License # 2679

Telephone: ( 770 ) 988-9555

in GEORGIA  
(state)

STATE OF Georgia, COUNTY OF Cobb

Before me, a Notary Public in and for such County, personally appeared Julian Grace, a Registered Land Surveyor, for the State of Georgia and

signed the above statement. In witness thereof, I have hereunto subscribed my name and affixed my Official Seal, at

Marietta, Georgia  
(city) (state)

the 9<sup>th</sup> day of October, 2003

Deborah A. Pinon  
Notary Public

My commission expires: 9/10/07

