

City and State in which pool is located: AUGUSTA GEORGIA  
 Name of Pool Owner or Operator: AUGUSTA RECREATION & PARKS Dept.  
 Mailing Address: P.O. BOX 5605  
 City, State, Zip: AUGUSTA GA 30916-5605  
 Pool Name: AUGUSTA AQUATICS CENTER  
 Pool Address (if different from above): 3157 DAMASCUS ROAD  
 City, State, Zip: AUGUSTA GEORGIA 30909

RELEVANT USA SWIMMING REGULATIONS

- Rule 103.3.1.C Dimensional Tolerance: Against the required length, a tolerance of plus (+) 0.03 meters (1 and 1/16ths of an inch) in a vertical plane extending 0.3 meters (12 inches) above and 0.8 meters (2 feet, 7 and 1/2 inches) below the surface of the water at all points of both end walls.
- Rules 103.3.1.D When automatic officiating equipment touch pads are used at one or both ends, the course shall be of such length that ensures the required distance between the two touch pads or between either pad and the opposite end of the course.
- Rule 104.2.2.C (4) (a) The exact length of the course, measured by a steel tape or other acceptable measuring device in feet and inches and fractions of an inch, or in meters and centimeters, must be attested to by an accredited surveyor or engineer.
- Rule 104.2.2.C (4) (b) A statement of the conditions under which the course was measured must be included.
- Rule 104.2.2.C (4) (c) Where a moveable bulkhead is used, course measurement of each lane must be confirmed at the conclusion of the session during which the time was achieved. Confirmation of length before sessions, and at the conclusion of the meet may be attested to by that person designated or approved by the Referee or meet committee, and such measurements shall be kept on file for twelve (12) months thereafter if a national or world record is claimed.

**NOTE:** If two or more racing courses are offered in the same pool (i.e., 50m x 25y), a separate form for each course must be filed.

MEASUREMENTS (ANSWER ALL QUESTIONS)

This is a      Long Course pool,  Short Course pool, and is  indoors,      outdoors.

With touch pads at  one end,      both ends,      without touch pads.

	LANE 1	LANE 2	LANE 3	LANE 4	LANE 5	LANE 6	LANE 7	LANE 8
YARDS	<u>25</u>	<u>25</u>	<u>25</u>	<u>25</u>	<u>25</u>	<u>25</u>	<u>25</u>	<u>25</u>
METERS	<u>    </u>	<u>    </u>	<u>    </u>	<u>    </u>	<u>    </u>	<u>    </u>	<u>    </u>	<u>    </u>

WATER DEPTH (IN FEET)

At starting end 7 ft; at turning end 7 ft; at course center 9 ft  
*[Signature]*

(continued on other side)

In any event, the provisions of USA Swimming Rules 103.3.1 and 109.2.2 as outlined on the previous page have been complied with in subject pool, with exceptions as follows:

Measurements were made on July 15, 20 1999 at 2:30 AM under normal competitive temperature conditions and to an accuracy of at least 0.1 feet (1.8 inch or 3.00 mm) in short course pool and at least 5.0mm in long course pool.

At the time of measurement, I was not in the employ of the pool builder.

The following equipment was used for measurements:

calibrated steel tape  
4 1/2 inch x 100 ft  
Check one:

Signed: [Signature]  
Title/Degree: Pres, Manager, and Assoc Registered Surveyor  
Address: 4253 Edgewinter Ct. Registered Engineer  
City/State/Zip: Kennesaw, GA 30144 License # 12552  
Telephone: (770) 424 1306 in GA  
(state)

STATE OF Georgia COUNTY OF Cobb

Before me, a Notary Public in and for such County, personally appeared David Markay Registered  
Engineer for the State of GA and

signed the above statement. In witness thereof, I have hereunto subscribed my name and affixed my Official Seal, at

Kennesaw GA  
(city) (state)

the 29th day of September, 2003

[Signature]  
Notary Public

My commission expires: 2003

# USA SWIMMING

## MEASUREMENT CERTIFICATION OF PERMANENT RACING COURSE

City and State in which pool is located: AUGUSTA GEORGIA  
 Name of Pool Owner or Operator: AUGUSTA RECREATION & PARKS DEPT.  
 Mailing Address: P.O. BOX 5605  
 City, State, Zip: AUGUSTA GA 30916-5605  
 Pool Name: AUGUSTA AQUATICS CENTER  
 Pool Address (if different from above): 3157 DAMASCUS ROAD  
 City, State, Zip: AUGUSTA GEORGIA 30909

### RELEVANT USA SWIMMING REGULATIONS

- Rule 103.3.1.C**      Dimensional Tolerance: Against the required length, a tolerance of plus (+) 0.03 meters (1 and 3/16ths of an inch) in a vertical plane extending 0.3 meters (12 inches) above and 0.8 meters (2 feet, 7 and 1/2 inches) below the surface of the water at all points of both end walls.
- Rules 103.3.1.D**      When automatic officiating equipment touch pads are used at one or both ends, the course shall be of such length that ensures the required distance between the two touch pads or between either pad and the opposite end of the course.
- Rule 104.2.2.C (4) (a)**      The exact length of the course, measured by a steel tape or other acceptable measuring device in feet and inches and fractions of an inch, or in meters and centimeters, must be attested to by an accredited surveyor or engineer.
- Rule 104.2.2.C (4) (b)**      A statement of the conditions under which the course was measured must be included.
- Rule 104.2.2.C (4) (c)**      Where a moveable bulkhead is used, course measurement of each lane must be confirmed at the conclusion of the session during which the time was achieved. Confirmation of length before sessions, and at the conclusion of the meet may be attested to by that person designated or approved by the Referee or meet committee, and such measurements shall be kept on file for twelve (12) months thereafter if a national or world record is claimed.

**NOTE:**      If two or more racing courses are offered in the same pool (i.e., 50m x 25y), a separate form for each course must be filed.

### MEASUREMENTS (ANSWER ALL QUESTIONS)

This is a  Long Course pool, \_\_\_\_\_ Short Course pool; and is  indoors, \_\_\_\_\_ outdoors.

With touch pads at  one end;  both ends; \_\_\_\_\_ without touch pads.

	LANE 1	LANE 2	LANE 3	LANE 4	LANE 5	LANE 6	LANE 7	LANE 8
YARDS								
METERS	<u>50</u>	<u>50</u>	<u>50</u>	<u>50</u>	<u>50</u>	<u>50</u>	<u>50</u>	<u>50</u>

### WATER DEPTH (IN FEET)

At starting end 7ft; at turning end 7ft; at course center 9 3/4ft

*CPM*

(continued on other side)

In my opinion, the provisions of USA Swimming Rules 103.3.1 and 103.2.2 as outlined on the previous page have been complied with in subject pool, with exceptions as follows:

Measurements were made on July 15 # 1999 at 2:30 AM/PM under normal competitive temperature conditions and to an accuracy of at least .01 feet (1/8 inch or 3.00 mm) in short course pool and at least 5.0mm in long course pool.

At the time of measurement, I was not in the employ of the pool builder.

The following equipment was used for measurements: Calibrated steel tape & plumb

Signed: [Signature] Check one DBS  
 Title/Degree: Pres. M.A.S. & Assoc. Registered Surveyor  
✓ Registered Engineer  
 Address: 4253 Edgewater Ct. License # 12550  
 City, State, Zip: Kennesaw, GA 30144 in GA  
 Telephone: (770) 424-1306 (State)

STATE OF \_\_\_\_\_ COUNTY OF \_\_\_\_\_  
 Before me, a Notary Public in and for such County, personally appeared David Markley Registered  
Engineer for the State of GA and  
 signed the above statement. In witness thereof, I have hereunto subscribed my name and affixed my Official Seal, at  
Kennesaw GA

the 29th day of September, 2003

[Signature]  
Notary Public

My commission expires: 2003